

# Introduction to Pinch by Linnhoff March

Pinch Technology provides a systematic methodology for energy saving in processes and total sites. The methodology is based on thermodynamic principles. Figure 1 illustrates the role of Pinch Technology in the overall process design. The process design hierarchy can be represented by the "onion diagram" [2, 3] as shown below. The design of a process starts with the reactors (in the "core" of the onion). Once feeds, products, recycle concentrations and flowrates are known, the separators (the second layer of the onion) can be designed. The basic process heat and material balance is now in place, and the heat exchanger network (the third layer) can be designed. The remaining heating and cooling duties are handled by the utility system (the fourth layer). The process utility system may be a part of a centralised site-wide utility system.




Figure 1: "Onion Diagram" of hierarchy in process design

A Pinch Analysis starts with the heat and material balance for the process. Using Pinch Technology, it is possible to identify appropriate changes in the core process conditions that can have an impact on energy savings (onion layers one and two). After the heat and material balance is established, targets for energy saving can be set prior to the design of the heat exchanger network. The Pinch Design Method ensures that these targets are achieved during the network design. Targets can also be set for the utility loads at various levels (e.g. steam and refrigeration levels). The utility levels supplied to the process may be a part of a centralised site-wide utility system (e.g. site steam system). Pinch Technology extends to the site level, wherein appropriate loads on the various steam mains can be identified in order to minimise the site wide energy consumption. Pinch Technology therefore provides a consistent methodology for energy saving, from the basic heat and material balance to the total site utility system.

This section contains a brief overview of how flowsheet data are used in pinch analysis. Data extraction is covered in more depth in Data Extraction Principles.

## Data Extraction Flowsheet

Data extraction relates to the extraction of information required for Pinch Analysis from a given process heat and material balance. Figure 2(a) shows an example process flow-sheet involving a two stage reactor and a distillation column. The process already has heat recovery, represented by the two process to process heat exchangers. The hot utility demand of the process is 1200 units (shown by H) and the cold utility demand is 360 units (shown by C). Pinch Analysis principles will be applied to identify the energy saving potential (or target) for the process and subsequently to aid the design of the heat exchanger network to achieve that targeted saving.




Figure 2: Data Extraction for Pinch Analysis

In order to start the Pinch Analysis the necessary thermal data must be extracted from the process. This involves the identification of process heating and cooling duties. Figure 2(b) shows the flow-sheet representation of the example process which highlights the heating and cooling demands of the streams without any reference to the existing exchangers. This is called the data extraction flow-sheet representation. The reboiler and condenser duties have been excluded from the analysis for simplicity. In an actual study however, these duties should be included. The assumption in the data extraction flow-sheet is that any process cooling duty is available to match against any heating duty in the process. No existing heat exchanger is assumed unless it is excluded from Pinch Analysis for specific reasons.

## Thermal Data

Stream No	Stream Type	Start Temperature ( $T_s$ ) (°C)	Target Temperature ( $T_t$ ) (°C)	Heat Capacity Flowrate (CP) (kW/°C)
1	Hot	180	80	20
2	Hot	130	40	40
3	Cold	60	100	80
4	Cold	30	120	36

DT min = 10°C Utilities Steam at 200°C, Cooling water at 25°C to 30°C

Table 1: Thermal Data required for Pinch Analysis

Table 1 shows the thermal data for Pinch Analysis. "Hot streams" are the streams that need cooling (i.e. heat sources) while "cold streams" are the streams that need heating (i.e. heat sinks). The supply temperature of the stream is denoted as  $T_s$  and target temperature as  $T_t$ . The heat capacity flow rate (CP) is the mass flowrate times the specific heat capacity i.e.

$$CP = C_p \times M$$

where  $C_p$  is the specific heat capacity of the stream (KJ/°C, kg) and  $M$  is the mass flowrate (kg/sec). The CP of a stream is measured as enthalpy change per unit temperature (kW/°C or equivalent units). For this example a minimum temperature difference of 10°C is assumed during the analysis which is the same as in the existing process, as highlighted in Figure 2(a). The hot utility is steam available at 200°C and the cold utility is cooling water available between 25°C to 30°C.

Starting from the thermal data for a process (such as shown in Table 1), Pinch Analysis provides a target for the minimum energy consumption. The energy targets are obtained using a tool called the "Composite Curves".

## construction of composite curves

Composite Curves consist of temperature-enthalpy (T-H) profiles of heat availability in the process (the "hot composite curve") and heat demands in the process (the "cold composite curve") together in a graphical representation. Figure 3 illustrates the construction of the "hot composite curve" for the example process, which has two hot streams (stream number 1 and 2, see Table 1). Their T-H representation is shown in Figure 3(a) and their composite representation is shown in Figure 3(b). Stream 1 has a CP of 20 kW/°C, and is cooled from 180°C to 80°C, releasing 2000kW of heat. Stream 2 is cooled from 130°C to 40°C and with a CP of 40kW/°C and loses 3600kW.




Figure 3: Construction of Composite Curves

The construction of the hot composite curve (as shown in Figure 3(b)) simply involves the addition of the enthalpy changes of the streams in the respective temperature intervals. In the temperature interval 180°C to 130°C only stream 1 is present. Therefore the CP of the composite curve equals the CP of stream 1 i.e. 20. In the temperature interval 130°C to 80°C, both streams 1 and 2 are present, therefore the CP of the hot composite equals the sum of the CP's of the two streams i.e. 20+40=60. In the temperature interval 80°C to 40°C only stream 2 is present, thus the CP of the composite is 40. The construction of the cold

composite curve is similar to that of the hot composite curve involving the combination of the cold stream T-H curves for the process.

## determining the energy targets

The composite curves provide a counter-current picture of heat transfer and can be used to indicate the minimum energy target for the process. This is achieved by overlapping the hot and cold composite curves, as shown in Figure 4(a), separating them by the minimum temperature difference  $DT_{min}$  ( $10^{\circ}C$  for the example process). This overlap shows the maximum process heat recovery possible (Figure 4(b)), indicating that the remaining heating and cooling needs are the minimum hot utility requirement ( $Q_{Hmin}$ ) and the minimum cold utility requirement ( $Q_{Cmin}$ ) of the process for the chosen  $DT_{min}$ .




Figure 4: Using the hot and cold composite curves to determine the energy targets

The composite curves in Figure 4 have been constructed for the example process (Figure 2 and Table 1). The minimum hot utility ( $Q_{Hmin}$ ) for the example problem is 960 units which is less than the existing process energy consumption of 1200 units. The potential for energy saving is therefore  $1200 - 960 = 240$  units by using the same value of  $DT_{min}$  as the existing process. Using Pinch Analysis, targets for minimum energy consumption can be set purely on the basis of heat and material balance information, prior to heat exchanger network design. This allows quick identification of the scope for energy saving at an early stage.

## the Pinch principle

The point where  $DT_{min}$  is observed is known as the "Pinch" and recognising its implications allows energy targets to be realised in practice. Once the pinch has been identified, it is possible to consider the process as two separate systems: one above and one below the pinch, as shown in Figure 5(a). The system above the pinch requires a heat input and is therefore a net heat sink. Below the pinch, the system rejects heat and so is a net heat source.




Figure 5: The Pinch Principle

In Figure 5(b), a amount of heat is transferred from above the pinch to below the pinch. The system above the pinch, which was before in heat balance with  $Q_{Hmin}$ , now loses a units of heat to the system below the pinch. To restore the heat balance, the hot utility must be increased by the same amount, that is, a units. Below the pinch, a units of heat are added to the system that had an excess of heat, therefore the cold utility requirement also increases by a units. In conclusion, the consequence of a cross-pinch heat transfer (a) is that both the hot and cold utility will increase by the cross-pinch duty (a).

For the example process (Figure 2, Figure 4) the cross pinch heat transfer in the existing process is equal to  $1200 - 960 = 240$  units.

Figure 5(b) also shows g amount of external cooling above the pinch and b amount of external heating below the pinch. The external cooling above the pinch of g amount increases the hot utility demand by the same amount. Therefore on an overall basis both the hot and cold utilities are increased by g amount. Similarly external heating below the pinch of b amount increases the overall hot and cold utility requirement by the same amount (i.e. b).

To summarise, the understanding of the pinch gives three rules that must be obeyed in order to achieve the minimum energy targets for a process:

- Heat must not be transferred across the pinch

- There must be no external cooling above the pinch
- There must be no external heating below the pinch

Violating any of these rules will lead to cross-pinch heat transfer resulting in an increase in the energy requirement beyond the target. The rules form the basis for the network design procedure which is described in Heat Exchanger Network Design. The design procedure for heat exchanger networks ensures that there is no cross pinch heat transfer. For retrofit applications the design procedure "corrects" the exchangers that are passing the heat across the pinch.

The energy requirement for a process is supplied via several utility levels e.g. steam levels, refrigeration levels, hot oil circuit, furnace flue gas etc. The general objective is to maximise the use of the cheaper utility levels and minimise the use of the expensive utility levels. For example, it is preferable to use LP steam instead of HP steam, and cooling water instead of refrigeration. The composite curves provide overall energy targets but do not clearly indicate how much energy needs to be supplied by different utility levels. This is illustrated in Figure 6.




Figure 6: Using Composite Curves for Multiple Utilities Targeting

The composite curves in Figure 6(a) provide targets for the extreme utility levels HP steam and cooling water. Figure 6(b) shows the construction of the composite curves if LP steam consumption replaces part of the HP steam consumption. The LP steam load is added to the hot composite curve as shown in Figure 6(b). As the LP steam consumption increases a  $DT_{min}$  temperature difference is reached between the composite curves. This is the maximum LP consumption that can replace the HP steam consumption. Every time a new utility level is added, the same procedure would have to be repeated in order to set the load on the new utility level. The shape of the composite curves will change with every new utility level addition and the overall construction becomes quite complex for several utility levels. The composite curves are therefore a difficult tool for setting loads for the multiple utility levels. What is required is a clear visual representation of the selected utilities and the associated enthalpy change without the disadvantages of using composite curves. For this purpose, the Grand Composite Curve is used.

## the Grand Composite Curve

The tool that is used for setting multiple utility targets is called the Grand Composite Curve, the construction of which is illustrated in Figure 7. This starts with the composite curves as shown in Figure 7(a). The first step is to make adjustments in the temperatures of the composite curves as shown in Figure 7(b). This involves increasing the cold composite temperature by  $\frac{1}{2} DT_{\min}$  and decreasing the hot composite temperature by  $\frac{1}{2} DT_{\min}$ .

This temperature shifting of the process streams and utility levels ensures that even when the utility levels touch the grand composite curve, the minimum temperature difference of  $DT_{\min}$  is maintained between the utility levels and the process streams. The temperature shifting therefore makes it easier to target for multiple utilities. As a result of this temperature shift, the composite curves touch each other at the pinch. The curves are called the "shifted composite curves". The grand composite curve is then constructed from the enthalpy (horizontal) differences between the shifted composite curves at different temperatures (shown by distance  $\alpha$  in Figure 7(b) and (c)). The grand composite curve provides the same overall energy target as the composite curves, the HP and refrigeration (ref.) targets are identical in Figure 7(a) and (c)




Figure 7: Construction of the Grand Composite Curve

The grand composite curve indicates "shifted" process temperatures. Since the hot process streams are reduced by  $\frac{1}{2} DT_{\min}$  and cold process streams are increased by  $\frac{1}{2} DT_{\min}$ , the construction of the grand composite curve automatically ensures that there is at least  $DT_{\min}$  temperature difference between the hot and cold process streams. The utility levels when placed against the grand composite curve are also shifted by  $\frac{1}{2} DT_{\min}$  - hot utility temperatures decreased by  $\frac{1}{2} DT_{\min}$  and cold utility temperatures increased by  $\frac{1}{2} DT_{\min}$ . For instance steam used at 200°C will be shown at 190°C if the  $DT_{\min}$  is 20°C. This shifting of utilities temperatures ensures that there is a minimum temperature difference of  $DT_{\min}$  between the utilities and the corresponding process streams. More importantly, when utility levels touch the grand composite curve,  $DT_{\min}$  temperature difference is maintained.

In PinchExpress there is a further refinement of this approach whereby the utilities are shifted by an amount that guarantees a user-specified approach temperature between the utility and the process streams. This approach temperature does not have to be the same as the process  $DT_{min}$  and can be different for each utility. For example, this is typically set at  $40^{\circ}C$  for flue gas, between  $10^{\circ}C$  and  $20^{\circ}C$  for steam and about  $3^{\circ}C$  for low temperature refrigeration. For more details see Typical  $DT_{min}$  values for matching utility levels against process streams.

## multiple utility targeting with the Grand Composite Curve

The grand composite curve provides a convenient tool for setting the targets for the multiple utility levels as illustrated in Figure 8.




Figure 8: Using the Grand Composite Curve for Multiple Utilities Targeting

Figure 8(a) shows a situation where HP steam is used for heating and refrigeration is used for cooling the process. In order to reduce the utilities cost, intermediate utilities MP steam and cooling water (CW) are introduced. Figure 8(b) shows the construction on the grand composite curve providing targets for all the utilities. The target for MP steam is set by simply drawing a horizontal line at the MP steam temperature level starting from the vertical (shifted temperature) axis until it touches the grand composite curve. The remaining heating duty is then satisfied by the HP steam. This maximises the MP consumption prior to the use of the HP steam and therefore minimises the total utilities cost. Similar construction is performed below the pinch to maximise the use of cooling water prior to the use of refrigeration as shown in Figure 8(b).

The points where the MP and CW levels touch the grand composite curve are called the "Utility Pinches" since these are caused by utility levels. A violation of a utility pinch (cross utility pinch heat flow) results in shifting of heat load from a cheaper utility level to a more expensive utility level. A "Process Pinch" is caused by the process streams, and as discussed earlier in The Pinch Principle. violation of a process pinch results in an overall heat load penalty for the utilities.

Figure 8(c) shows a different possibility of utility levels where furnace heating is used instead of HP steam. Considering that furnace heating is more expensive than MP steam, the use of MP steam is maximised. In the temperature range above the MP steam level, the heating duty has to be supplied by the furnace flue gas. The flue gas flowrate is set as shown in Figure 8(c) by drawing a sloping line starting from the MP steam temperature to theoretical flame temperature ( $T_{TFT}$ ). If the process pinch temperature is above the flue gas corrosion temperature, the heat available from the flue gas between MP steam and pinch temperature can be used for process heating. This will reduce the MP steam consumption as shown in Figure 8(c). The MP steam load needs to be adjusted accordingly.

In summary the grand composite curve is one of the basic tools used in pinch analysis for selection of appropriate utility levels and for targeting for a given set of multiple utility levels. The targeting involves setting appropriate loads for the various utility levels by maximising cheaper utility loads and minimising the loads on expensive utilities.

The best design for an energy efficient heat exchange network will often result in a trade off between the equipment and operating costs. This is dependent on the choice of the  $DT_{min}$  for the process. The lower the  $DT_{min}$  chosen, the lower the energy costs, but conversely the higher the heat exchanger capital costs, as lower temperature driving forces in the network will result in the need for greater area. A large  $DT_{min}$ , on the other hand, will mean increased energy costs as there will be less overall heat recovery, but the required capital costs will be less. The trade-off is further complicated in a retrofit situation, where a capital investment has already been made. This section explains a rational approach to the complex task of capital-energy trade-offs.

## new designs

So far the use of Pinch Analysis has been considered for setting the energy targets for a process. These targets are dependent on the choice of the  $DT_{min}$  for the process. Lowering the value of  $DT_{min}$  lowers the target for minimum energy consumption for the process. In this section the concept of heat exchanger network capital cost targets for the process are discussed. For certain types of applications such as refinery crude preheat trains, where there are few matching constraints between hot and cold streams, it is possible to set capital cost targets in addition to the energy targets. This allows the consideration of the trade-offs between capital and energy in order to obtain an optimum value of  $DT_{min}$  ahead of network design.

This functionality is provided in the SuperTarget Process module developed by Linnhoff March.

## setting area targets

The composite curves make it possible to determine the energy targets for a given value of  $DT_{min}$ . The composite curves can also be used to determine the minimum heat transfer area required to achieve the energy targets:

$$\text{Network Area, } A_{\min} = \sum_i \left[ \frac{1}{\Delta T_{LM}} \sum_j \frac{q_j}{h_j} \right]$$

where:

- $i$ : denotes  $i$ th enthalpy interval
- $j$ :  $j$ th stream
- $D$  TLM: log mean temperature difference in interval
- $q_j$ : enthalpy change of  $j$ th stream
- $h_j$ : heat transfer coefficient of  $j$ th stream

This area target is based on the assumption that "vertical" heat exchange will be adopted between the hot and the cold composite curves across the whole enthalpy range as shown in Figure 9. This vertical arrangement, which is equivalent to pure counter-current area within the overall network, has been found to give a minimum total surface area. For a case where the process streams have uniform heat transfer coefficients this is rigorous. In a new design situation, where there are no existing exchangers, it should be possible to design a network that is close to these targets.




Figure 9: Vertical heat transfer between the composite curves leads to minimum network surface area

### setting minimum number of units target

It is also possible to set a target for the minimum number of heat exchanger units in a process. The minimum number of heat exchange units depends fundamentally on the total number of process and utility streams (N) involved in heat exchange. This can also be determined prior to design by using a simplified form of Euler's graph theorem [2, 3].

$$U_{\min} = N - 1$$

where:

- $U_{\min}$ : Minimum number of heat exchanger units
- N: Total number of process and utility streams in the heat exchanger network

This equation is applied separately on each side of the pinch, as in an MER (minimum energy requirement) network there is no heat transfer across the pinch and therefore the network is divided into two independent problems: one above, and one below the pinch.

### determining the capital cost target

The targets for the minimum surface area and the number of units ( $U_{\min}$ ) can be combined together with the heat exchanger cost law equations [8] to generate the targets for heat exchanger network capital cost. The capital cost target can be super-imposed on the energy cost targets to obtain the minimum total cost target for the network as shown in Figure 10.




Figure 10: The trade-off between energy and capital costs gives the optimum  $\Delta T_{min}$  for minimum cost in new designs

This provides an optimum  $\Delta T_{min}$  for the network ahead of design [3, 8]. It is important to note that the capital cost targeting algorithm is based on the simplifying assumption that any hot stream can match against any cold stream. It does not consider matching constraints between specific hot and cold streams. Therefore the capital cost targeting technique and  $\Delta T_{min}$  optimisation is particularly applicable for systems with fewer matching constraints such as atmospheric and vacuum distillation preheat trains, FCC unit, etc..

The description above has assumed pure counter-current heat exchangers. However, in SuperTarget Process there is an additional option to target based on shell and tube exchangers with one shell pass and two tube passes. This is the most common exchanger type found in industrial use.

Pinch Technology is applicable to both new design and retrofit situations. The number of retrofit applications is much higher than the number of new design applications.

In this section techniques are discussed for setting targets for energy saving for an existing plant based on capital-energy trade-off for retrofit projects. The SuperTarget Process module contains tools which employ these techniques.

## retrofit targeting based on capital-energy trade-off

Figure 11 provides an understanding of the capital - energy trade-off for a retrofit project using an area-energy plot.




Figure 11: Capital energy trade off for retrofit applications

The curve (enclosing the shaded area) is based on new design targets for the process. The shaded area indicates performance better than the new design targets (which is infeasible for an existing plant). An existing plant will typically be located above the new design curve. The closer the existing plant is to the new design curve the better the current performance. In a retrofit modification, for increased energy saving, the installation of additional heat exchanger surface area is expected. The curve for the additional surface area that is closest to the new design area-energy curve provides the most efficient route for investment (good economics). The following section explains how such a curve for a retrofit application can be developed ahead of design.


## maintaining area efficiency

Figure 12 depicts an approach for retrofit targeting based on the concept of "area efficiency". An area efficiency factor  $\alpha$  can be determined for an existing network according to the following equation:

$$\alpha = \left[ \frac{A_t}{A_{ex}} \right]_{E_{ex}} = \left[ \frac{A_1}{A_2} \right]_{E_{ret}}$$

where:

- $E_{ex}$  : Existing energy consumption
- $A_{ex}$  : Existing surface area of the network
- $A_t$  : Target surface area for the new design at the existing energy consumption ( $E_{ex}$ )



$$\alpha = \left[ \frac{A_t}{A_{ex}} \right]_{E_{ex}} = \left[ \frac{A_1}{A_2} \right]_{E_{ret}}$$

Figure 12: Area Efficiency concept

Area efficiency determines how close the existing network is to the new design area target. In order to set a retrofit target, one approach is to assume that the area efficiency of the new installed area is the same as the existing network as shown in Figure 12 [3, 9].

## payback

From the area-energy targeting curve the saving versus investment curve for the retrofit targeting can be developed. This is shown in Figure 13.




Figure 13: Targeting for retrofit applications

Various pay-back lines can be established as shown in the figure. Based on the specified pay-back or investment limit, the target energy saving can be set. This will in turn determine the targeted  $DT_{min}$  value for the network. From the target  $DT_{min}$  value, the cross pinch heat flow and the cross pinch heat exchangers that need to be corrected are calculated. This forms the basis for the network design modification as further discussed in Heat Exchanger Network Design.

This targeting procedure is based on the constant  $a$  assumption. This assumption is particularly valid if the  $a$  for the existing network is high (say above 0.85). In situations where the existing  $a$  is low (say 0.6) the constant  $a$  assumption is conservative. In such cases it can be assumed that the additional area can be installed at a higher area efficiency (say 0.9 or 1).

The retrofit targeting procedure is particularly applicable for processes with few matching constraints such as atmospheric and vacuum distillation preheat trains. For other applications the targeting methods described in the following sections are more applicable.

## retrofit targeting based on $DT_{min}$ - energy curves

Exchanger capital cost and heat transfer information is required to set the retrofit targets based on capital energy trade-off. In addition, the process may have heat exchanger matching constraints which create inaccuracies in the capital cost targets as described in Payback above. Finally the project time constraints may limit the use of the capital cost targets for retrofit targeting. In this section a simpler approach to retrofit targeting based on the analysis of energy target variation with  $DT_{min}$  is described.




Figure 14: Targeting for retrofit applications

Figure 14 shows an example of a  $DT_{min}$ - Energy plot for a process. The plot can be directly obtained from the process composite curves. The vertical axis can represent energy target or energy cost. Existing design corresponds to the  $DT_{min}$  of 36°C between the composite curves. The plot shows that the variation of energy target (or energy cost) is quite sensitive to  $DT_{min}$  in the temperature range of 30°C to 20°C. However between 20°C and 8°C the energy target is not sensitive to  $DT_{min}$ . On the other hand the capital cost may rise substantially in this region. It therefore implies that 20°C is an appropriate target for the retrofit.

Although the  $DT_{min}$  - Energy plot does not directly account for the capital cost dimension, it is expected that dominant changes in the energy dimension will have an impact on the capital-energy trade-off. The above approach, coupled with previous application experience on similar processes (see Retrofit targeting based on experience  $DT_{min}$  values) provides practical targets in many situations.

## DTmin calculation in PinchExpress

In PinchExpress, an option for automatically calculating a suitable  $DT_{min}$  for a process is available. This calculation is done by considering an area-energy trade-off based on one of two benchmark processes built in to PinchExpress. These processes are used as they represent two extremes of plant economics.

A Crude Oil Project is used as the benchmark for above ambient processes because it displays a well behaved trade-off between area cost and capital cost. In addition, the optimum  $DT_{min}$  for this process is high because the composite curves are narrow, leading to high area requirements. This means that it represents one extreme of plant economics, where the optimum  $DT_{min}$  can be greater than 30°C. Using this benchmark will ensure that a lower  $DT_{min}$  is selected for an above ambient process with diverging composite curves.

An Ethylene cold-end project is used as the benchmark for below ambient processes because it requires refrigeration utilities at temperatures as low as -100°C. This is very expensive so the economic  $DT_{min}$  is sensitive to the cost of the refrigeration utilities. This therefore represents the other extreme of plant economics, where driving forces are tight to minimise expensive refrigeration. The optimum  $DT_{min}$  for an ethylene cold-end may be as low as 2°C. Using this as a benchmark will ensure that other processes requiring less extreme refrigeration will use a higher  $DT_{min}$ .

A process that is similar to one of these two will be adequately represented by the benchmark trade-off between area cost and energy cost. This trade-off can be fine tuned by changing the benchmark  $DT_{min}$  values.

For each benchmark, PinchExpress defines two different  $DT_{min}$  values, one for a New Design and one for a Retrofit project. The values for retrofit are usually slightly higher than those for New Design (i.e. saving less energy) due to the difficulty of re-arranging the existing heat exchangers.

A process that is significantly different from either benchmark will fit into one of the following categories:

1. It has divergent composite curves and scope for use of intermediate utilities. For these processes the optimum  $DT_{min}$  is usually determined by a sharp change in the plot of  $DT_{min}$  vs. Energy Cost. This means that the trade-off between Energy Cost and Capital Cost can vary significantly without hardly changing the optimum  $DT_{min}$  at all. In other words, the answer is not very sensitive to the trade-off so the benchmark values are perfectly adequate.
2. It is a mixture of above and below ambient parts. In this case PinchExpress will automatically use both benchmarks when determining the trade-off between energy cost and capital cost.

From this discussion it should now be clear that PinchExpress has sufficient information to calculate a suitable  $DT_{min}$  for any type of process. Most importantly, this can be done without knowing specific information about individual heat exchanger costs or heat transfer coefficients.

A final point worth making is that this new method can be regarded as a combination of all the other methods described in this document, for the following reasons:

1. The use of benchmark processes is analogous to the use of experience values (see next section).
2. For a refinery process the method will explore the trade-off between area cost and energy cost, in a similar manner to that described in earlier sections.
3. For a petro-chemical process the method will identify sharp changes in the plot of Energy Cost vs.  $DT_{min}$ , which is the method described previously in Retrofit targeting based on  $DT_{min}$  - Energy curves.

## Retrofit targeting based on experience $DT_{min}$ values

It is expected that retrofit projects involving similar cost scenarios (fuel and capital costs etc.), and similar levels of process technology may result in similar target  $DT_{min}$  values. In such cases previous applications experience provides a useful source of information for setting the target  $DT_{min}$  for the process.

Usually similar processes have similar shapes of composite curves. For example for atmospheric distillation units, the composite curves tend be "parallel" to each other due to the similarity of the mass flows between the feed and the products of distillation. The shape of the composite curves influences the temperature driving force distribution in the process and therefore the heat exchanger network capital cost. Figure 15 illustrates the impact of the shape of the composite curves on the target  $DT_{min}$  value.




Figure 15: Effect of shape of composite curves on optimum process  $DT_{min}$

For wide (or divergent) composite curves, even at low values of  $DT_{min}$ , the overall temperature driving force is quite high. Conversely for tight (or parallel) composite curves the heat exchanger capital cost will be quite high at low  $DT_{min}$  values. Such an understanding coupled with previous applications experience can be quite useful in setting practical retrofit targets.

The following tables detail Linnhoff March's experience  $DT_{min}$  values. It is important to note that although experience based  $DT_{min}$  values can provide practical targets for retrofit modifications, in certain situations it may result in non-optimal solutions and therefore loss of potential opportunities. It is therefore recommended that the use of experience based  $DT_{min}$  is treated with caution and that as much as possible the choice is backed up by quantitative information (such as  $DT_{min}$  versus energy plot etc.).

## Typical $DT_{min}$ values for various types of processes

Table 2 shows typical  $DT_{min}$  values for several types of processes. These are values based on Linnhoff March's application experience.

No	Industrial Sector	Experience $DT_{min}$ Values	Comments
1	Oil Refining	20-40°C	Relatively low heat transfer coefficients, parallel composite curves in many applications, fouling of heat exchangers Reboiling and condensing duties provide better heat transfer coefficients, low fouling
2	Petrochemical	10-20°C	As for Petrochemicals
3	Chemical	10-20°C	Power requirement for refrigeration system is very expensive. $DT_{min}$ decreases with low refrigeration temperatures
4	Low Temperature Processes	3-5°C	

Table 2: Typical  $DT_{min}$  values for various types of processes

## Typical DT<sub>min</sub> values used for matching utility levels against process streams

Below are typical DT<sub>min</sub> values for matching utilities against process streams. These experience based DT<sub>min</sub> values are useful in identifying targets for appropriate utility loads at various utility levels.

Match	DT <sub>min</sub>	Comments
Steam against Process Stream	10-20°C	Good heat transfer coefficient for steam condensing or evaporation
Refrigeration against Process Stream	3-5°C	Refrigeration is expensive
Flue gas against Process Stream	40°C	Low heat transfer coefficient for flue gas
Flue gas against Steam Generation	25-40°C	Good heat transfer coefficient for steam
Flue gas against Air (e.g. air preheat)	50°C	Air on both sides. Depends on acid dew point temperature
CW against Process Stream	15-20°C	Depends on whether or not CW is competing against refrigeration. Summer/Winter operations should be considered

Table 3: Typical DT<sub>min</sub> values for process-utility matches

## Typical DT<sub>min</sub> values used in retrofit targeting of various refinery processes

Table 4 shows typical DT<sub>min</sub> values used in retrofit targeting of refinery processes, based on Linnhoff March's refinery studies. The comments provide qualitative explanation for the choice of the DT<sub>min</sub> value.

Process	DT <sub>min</sub>	Comments
CDU	30-40°C	Parallel (tight) composites
VDU	20-30°C	Relatively wider composites (compared to CDU) but lower heat transfer coefficients
Naphtha Reformer/Hydrotreater Unit	30-40°C	Heat exchanger network dominated by feed-effluent exchanger with DP limitations and parallel temperature driving forces. Can get closer DT <sub>min</sub> with Packinox exchangers (up to 10-20°)
FCC	30-40°C	Similar to CDU and VDU

Gas Oil Hydrotreater/Hydrotreater	30-40°C	Feed-effluent exchanger dominant. Expensive high pressure exchangers required. Need to target separately for high pressure section (40°C) and low pressure section (30°C).
Residue Hydrotreating	40°C	As above for Gas Oil Hydrotreater/Hydrotreater
Hydrogen Production Unit	20-30°C	Reformer furnace requires high DT (30-50°C). Rest of the process: 10-20°C.

Table 4: Typical  $DT_{min}$  values for Refinery Processes

The minimum energy requirements set by the composite curves are based on a given process heat and material balance. By changing the heat and material balance, it is possible to further reduce the process energy requirement. There are several parameters that could be changed such as distillation column operating pressures and reflux ratios, feed vaporisation pressures, pump-around flowrates, reactor conversion etc. The number of choices is so large that it seems impossible to confidently predict the parameters that could be changed to reduce energy consumption. However, by applying the thermodynamic rules based on Pinch Analysis, it is possible to identify changes in the appropriate process parameter that will have a favourable impact on energy consumption. This is called the "plus-minus principle".

### The plus-minus principle for process modifications

The heat and material balance of the process determines the composite curves of the process. As the heat and material balance change, so do the composite curves. Figure 16(a) summarises the impact of these changes on the process energy targets.

In general any :

- Increase in hot stream duty above the pinch.
- Decrease in cold stream duty above the pinch.

will result in a reduced hot utility target, and any:

- Decrease in hot stream duty below the pinch.
- Increase in cold stream duty below the pinch.

will result in a reduced cold utility target.

This is termed as the "+/- principle" for process modifications. This simple principle provides a definite reference for any adjustment in process heat duties, such as vaporisation of a recycle, pump-around condensing etc., and indicates which modifications would be beneficial and which would be detrimental.




Figure 16: Modifying the process, (a) The +/- principle for process modifications (b) Temperature changes can affect the energy targets only if streams are shifted through the pinch

Often it is possible to change temperatures rather than heat duties. It is clear from Figure 16(a) that temperature changes that are confined to one side of the pinch will not have any effect on the energy targets. Figure 16(b) illustrates how temperature changes across the pinch can change the energy targets. Due to the reduction in feed vaporisation (FV) pressure, the feed vaporisation duty has moved from above to below the pinch. As a result the process energy target is reduced by the vaporisation duty. This can be considered as an application of +/- principle twice.

Thus the beneficial pattern for shifting process temperatures can be summarised as follows:

- Shift hot streams from below the pinch to above the pinch
- Shift cold streams from above the pinch to below the pinch

The +/- principle is in line with the general idea that it ought to be beneficial to increase the temperature of hot streams (this must make it easier to extract heat from them) and that likewise reduce the temperature of the cold streams. Changing the temperature of streams in this fashion will improve the driving forces in the heat exchanger network but can also decrease the energy targets if the temperature changes extend across the pinch. The designer can predict which modifications would be beneficial, detrimental, or inconsequential ahead of design.

## Distillation Columns

Distillation columns are one of the major consumers of energy in chemical processes. In this section the principles for appropriate modification of distillation columns and their integration with the remaining process are considered. Firstly pinch analysis for stand-alone modification of distillation columns is considered, followed by principles for appropriate integration of distillation columns with the remaining process.

The SuperTarget Column module developed by Linnhoff March provides an advanced software tool for the implementation of standalone column modifications. PinchExpress and SuperTarget Process provide tools for assessing the impact of column heat integration within a process.

#### Stand-alone column modifications

There are several options for improving energy efficiency of distillation columns. These include reduction in reflux ratio, feed conditioning and side condensing/reboiling etc. Using pinch analysis it is possible to identify which one of these modifications would be appropriate for the column and what would be the extent of the modification.




Figure 17: Procedure for obtaining Column Grand Composite Curve

## The Column grand composite curve

The tool that is used for column thermal analysis is called the Column Grand Composite Curve (CGCC) [15], an example of which is shown in Figure 17. The procedure for obtaining the CGCC starts with a converged column simulation as shown in the figure. From the simulation, the necessary column information is extracted on a stage-wise basis. This information can then be processed (for example by using the SuperTarget Column module) to generate the CGCC as shown in Figure 17(b).

The CGCC, like the grand composite curve for a process, provides a thermal profile for a column and is used for identifying appropriate targets for the column modifications such as side condensing and reboiling as shown in the figure. In a normal column energy is supplied to the column at reboiling and condensing temperatures. The CGCC relates to minimum thermodynamic loss in the column or "Ideal Column" operation (see Figure 17(c)). For ideal column operation the column requires infinite number of stages and infinite number of side reboilers and condensers as shown in Figure 17(c). In this limiting condition, the energy can be supplied to the column along the temperature profile of the CGCC instead of supplying it at extreme reboiling and condensing temperatures. The CGCC is plotted in either T-H or Stage-H dimensions. The pinch point on the CGCC is usually caused by the feed.

### Modifications using the Column grand composite curve

Figure 18 shows the use of the CGCC in identifying appropriate stand-alone column modifications. Firstly, the feed stage location of the column must be optimised in the simulation prior to the start of the column thermal analysis. This can be carried out by trying alternate feed stage locations in simulation and evaluating its impact on the reflux ratio. The feed stage optimisation is carried out first since it may strongly interact with the other options for column modifications. The CGCC for the column is then obtained.




Figure 18: Using Column Grand Composite Curve to identify column modifications

As shown in Figure 18(a) the horizontal gap between the vertical axis and CGCC pinch point indicates the scope for reflux improvement in the column. As the reflux ratio is reduced, the CGCC will move close to the vertical axis. The scope for reflux improvement must be considered first prior to other thermal modifications since it results in direct heat load savings both at the reboiler and the condenser level. In an existing column the reflux can be improved by addition of stages or by improving the efficiency of the existing stages.

After reflux improvement the next priority is to evaluate the scope for feed preheating or cooling (see Figure 18(b)). This is identified by a "sharp change" in the stage-H CGCC shape close to the feed as shown in the figure with a feed preheating example. The extent of the sharp change approximately indicates the scope for feed preheating. Successful feed preheating allows heat load to be shifted from reboiler temperature to the feed preheating temperature. Analogous procedure applies for feed pre-cooling.

After feed conditioning, side condensing/reboiling should be considered. Figure 18(c) describes CGCC's which show potential for side condensing and reboiling. An appropriate side reboiler allows heat load to be shifted from the reboiling temperature to a side reboiling temperature without significant reflux penalty.

In general, feed conditioning offers a more moderate temperature level than side condensing/reboiling. Also feed conditioning is external to the column and is therefore easier to implement than side condensing and reboiling. The sequence for the different column modifications can be summarised as follows:

1. Feed stage location
2. Reflux improvement
3. Feed preheating/cooling
4. Side condensing/reboiling

## Column integration

In the previous section, ways of improving column thermal efficiency by stand alone column modifications were considered. In many situations it is possible to further improve the overall energy efficiency of the process by appropriate integration of the column with the background process. By "column integration" a heat exchange link is implied between the column heating/cooling duties and the process heating/cooling duties or with the utility levels. Figure 19 summarises the principles for appropriate column integration with the background process.




Figure 19: Appropriate Integration of a distillation column with the background process

Figure 19(a) shows a column with a temperature range across the pinch temperature of the background process. The background process is represented by its grand composite curve. The overall energy consumption in this case is equal to that of the column plus the background process. In other words, there is no benefit in integrating the column with the background process. The column is therefore inappropriately placed as regards its integration with the background process.

Figure 19(b) shows the CGCC of the column. The CGCC indicates a potential for side condensing. The side condenser opens up an opportunity for integration between the column and the background process. Compared to Figure 19(a) the overall energy consumption (column + background process) has been reduced due to the integration of the side condenser.

As an alternative the column pressure could be increased. This will allow a complete integration between the column and the background process via the column condenser (Figure 19(c)). The column is now on one side of the pinch (not across the pinch). The overall energy consumption (column + background process) equals the energy consumption of the background process. Energy-wise the column is running effectively for free. The column is therefore appropriately placed as regards its integration with the background process.

To summarise, the column is inappropriately placed if it is placed across the pinch and has no potential for integration with the background process via side condensers or reboilers etc. The integration opportunities are enhanced by stand-alone column modifications such as feed conditioning and side condensing/reboiling. The column is appropriately placed if it lies on one side of the pinch and can be accommodated by the grand composite of the background process.

Appropriate column integration can provide substantial energy benefits. However these benefits must be compared against associated capital investment and difficulties in operation. In some cases it is possible to integrate the columns indirectly via the utility system which may reduce operational difficulties.

The principle of appropriate column integration can also be applied to other thermal separation equipment such as evaporators [7].

Heat engines and heat pumps constitute key components of the process utility system. In this section, principles based on pinch analysis for appropriate integration of heat engines and heat pumps with processes, will be considered.

## Appropriate integration of heat engines

A heat engine in a process context can have two objectives; supplying for process heat demand and generation of power. Appropriate integration of heat engines with the process provides the most energy efficient combination of these objectives. By "integration" here a heat exchange link is implied between the heat engine and the process. Figure 20 shows three possibilities of integration of a heat engine with a process. The process is represented by two regions: one above and other below the pinch. If a heat engine is integrated across the pinch (Figure 20(a)), it does not provide any benefit due to integration. The overall energy consumption is as good as operating the heat engine independent of the process.

Integrate across the pinch    Integrate above the pinch    Integrate below the pinch




Figure 20: Appropriate Placement Principle for heat engines

If the heat engine is placed so that it rejects heat into the process above the pinch temperature (Figure 20(b)), it transfers the heat to process heat sink, thereby reducing the hot utility demand. Due to the heat engine the overall hot utility requirement is only increased by  $W$  (i.e. the shaftwork). This implies a 100% efficient heat engine. The heat engine is therefore appropriately placed.


If the heat engine is placed so that it takes in energy from the process below the pinch temperature (Figure 20(c)), it takes that energy from an overall process heat source. Here the engine runs on process heat free of fuel cost and reduces the overall cold utility requirement by  $W$ . The heat engine is again appropriately placed.

To summarise, appropriate placement of heat engines is either above the pinch or below the pinch but not across the pinch.


The above mentioned principle provides basic rules for integration of heat engines. The rules assume that the process is able to absorb all the heat rejected by the heat engine. The designers therefore must use the grand composite curve in setting the integration of the heat engine with the process.

## Identifying opportunities for heat engine placement

Figure 21 shows the placement of steam and gas turbines against the grand composite curve. Both the placements are on one side of the pinch and are therefore appropriate. Figure 21(a) shows the integration of a steam turbine system with a process. Starting from the targets for steam demands ( $A$  and  $B$ ) the key parameters for the steam turbine system are set. For a given boiler steam pressure, the overall fuel demand and shaftwork ( $W$ ) can be calculated. The overall fuel demand =  $A+B+W+Q_{LOSS}$  where  $Q_{LOSS}$  is the heat loss from the boiler. Thus targets are set for the overall fuel demand and shaftwork potential for the process starting from the grand composite curve.



(a)



(b)

Figure 21: Placement of steam and gas turbines against the grand composite curve

Figure 21(b) shows an example of appropriate integration of gas turbine with the process. The exhaust heat of the gas turbine is utilised for satisfying process heating demand. This is represented by placement of thermal profile of the exhaust heat against the grand composite curve as shown in the figure. The gas turbine exhaust heat therefore saves the equivalent hot utility demand of the process. The heat from the gas turbine fuel demand is obtained by the sum of process heating demand ( $A$ ), shaftwork ( $W$ ) and the heat loss below the pinch temperature ( $Q_{LOSS}$ ).

## Appropriate integration of heat pumps

A heat pump accepts heat at a lower temperature and, by using mechanical power, rejects the heat at a higher temperature. The rejected heat is then the sum of the input heat and the mechanical power. Heat pumps provide a way of using waste heat for useful process heating. The pinch analysis principle for integration of heat pumps is useful in setting key design parameters for the heat pumps.

Figure 22 shows the three arrangements that a heat pump may take relative to the pinch. First, heat can be taken from above the pinch and rejected at a higher temperature also above the pinch (Figure 22(a)). This saves hot utility by the amount  $W$  but only at the expense of an equal input of power  $W$ . Because power is much more expensive than heat (typically 4 to 5 times), this is not an efficient solution.




Figure 22: Placement of heat pumps.

Second, the heat pump can take in heat from below the pinch and reject it at a higher temperature, also below the pinch (Figure 22(b)). This is even more inefficient because  $W$  units of heat (from power) is rejected to a part of the process that already had an excess of heat (remember, the process below the pinch is a heat source). The third option is to take in heat from below the pinch and reject it at a temperature above the pinch (Figure 22(c)). This provides savings in both hot and cold utilities because it is pumping heat from a source (below the pinch) to a sink (above the pinch). The appropriate way to integrate a heat pump is therefore across the pinch. It is important to note here that "pinch" denotes process as well as utility pinch. The overall economics of the heat pump however, depend on the heat savings due to heat pump compared with the cost of power input and capital cost of the heat pump and associated heat exchangers.

## Identifying opportunities for heat pump placement

As discussed previously, the economics of the heat pump placement depend on the balance between process heat savings versus power requirement for heat pumping. In order to make the heat pump option economical a large process heat duty and small temperature differential across the heat pump are needed. By examining the grand composite curve of a process, it is possible to identify quickly when opportunities for introducing a heat pump may exist. Consider Figure 23(a). The grand composite curve shows a region of small temperature change and large enthalpy change above and below the pinch. This pointed "nose" at the pinch indicates that a heat pump can be installed across the small temperature change for a relatively large saving in heating and cooling demand. The energy saving will therefore be high for a relatively small expense in power (high coefficient of performance). The diagram in Figure 23(b), however, shows that the heat pump option may be uneconomical since the temperature differential across the heat pump is quite large which will result in high power requirement for the heat pump.




Figure 23: A pointed 'nose' at the process or utility pinch indicates a good heat pump opportunity

Refrigeration systems constitute another class of heat pumping applicable to sub-ambient temperature regions. The principles of appropriate placement as discussed in this section are also applicable to refrigeration systems. In addition techniques have been developed which provide a more detailed approach for the placement of refrigeration levels against the grand composite curve [11, 12].

The figure below provides an overview of key steps in pinch technology.




Figure 24: Key steps in Pinch Technology

So far the first two steps have been considered, namely, data extraction and analysis. Data extraction involves translation of flow-sheet information into relevant thermal and cost information required for the application of pinch technology. For more information on the principles of converting flowsheet data to pinch analysis data see Data Extraction Principles. The second step in pinch technology is pinch analysis based on targets. This involves targeting for energy, trade-offs in targeting mode between capital and energy, targeting for process modifications and targeting for multiple utility levels and placement of heat engines and heat pumps.

In the analysis stage the objective is to explore various options for process improvement quickly and easily using targeting, without getting into the detail of specific flow-sheet changes. This allows quick screening of various options for process improvement such as energy recovery, process modifications, utility system integration etc. The key improvement options identified in the analysis stage need to be implemented in design. In this section the focus is on the design aspect of pinch technology. This translates the ideas for improvement obtained during the analysis/targeting stage into specific modifications of the heat exchanger network.

The heat exchanger network design procedure is based upon pinch analysis principles and is called the Pinch Design Method. The method systematically leads the engineer to good network designs that achieve the energy targets within practical limits. The network design procedure uses a special representation for heat exchanger networks called the Grid Diagram. The network design procedures for new design and retrofit design are discussed separately in the following sections. Before this however, some further consideration is given to network representation.

## The Difference Between Streams and Branches

Previous sections have described how Pinch Technology uses stream data and utility data to represent a process design. This representation is sufficient for targeting, which only needs to know about the heat sources and sinks at each temperature interval. It is not complete enough, however, to represent a network of heat exchanger matches because it does not contain any information on stream splits and mixers. An additional structure must therefore be overlaid on top of the stream and utility data. The features of this additional representation used in PinchExpress are as follows:

- A stream or utility is split into a number of branches. Initially, each stream has only one branch. More are created, however, as splits and mixers are placed on the stream.
- The first branch on a stream either ends at a split or goes to the end of the stream.
- New branches are created each side of a split or mix. A branch never continues through a split or mix.
- Branches do, however, continue straight through heat exchanger matches. A branch never divides at a match.

Each branch has the following data associated with it:

- TS: The source temperature of the branch. For a branch at the start of a stream this is the same as the stream TS. For others, it is the temperature out of the split or mix.
- TT: The target temperature of the branch. For a branch at the end of a stream this is the same as the stream TT. For others, it is the temperature into the split or mix.
- FF: The flow fraction of the branch, relative to the original stream. This is determined by the upstream splits and mixers.
- Number: The branch number. In PinchExpress, this is created automatically and cannot be changed.
- Name: The branch name. This is generated automatically by PinchExpress but can, in most cases,

be changed. The first branch on a stream has the same name as the stream.

At any temperature the Mass Flow Heat Capacity of a branch is defined as follows:

Branch CP = FF \* Stream CP at the same temperature

- The branch structure does not change the basic stream data. Changes in the stream duties continue to affect the branch duties and CPs.
- All the branches into a mix must belong to the same stream. Mixers between streams are NOT allowed.
- A branch cannot mix back in upstream of its starting point. Stream loops such as this are NOT allowed.

## The Grid Diagram for heat exchanger network representation

Figure 25 shows the Grid Diagram representation of a heat exchanger network.




Figure 25: The Grid diagram for easier representation of the heat exchanger network

The hot streams are shown at the top of the figure, running from left to right. Cold streams run across the bottom, from right to left. A heat exchanger transferring heat between the process streams is shown by a vertical line joining circles on the two matched streams. A heater is shown as a single blue circle with an arrow pointing down and a cooler is shown as a single red circle with an arrow pointing up.

The pinch principle explains how the process must be separated into two regions, above and below the pinch, for network design in order to achieve the energy targets. The understanding of the pinch location is therefore very important for network design.

In the grid diagram the process pinch location is shown by a dashed vertical line cutting the process into two parts. The pinch hot and cold temperatures as determined from the composite curves are shown on the grid diagram (shown as 90°C and 80°C respectively in Figure 25). The difference between the hot and cold pinch temperatures equals  $DT_{min}$  as seen on the composite curves. The process below the pinch (heat source) is shown on the right whilst the process above the pinch (heat sink) is shown on the left. From this it can be seen that the horizontal axis implies a temperature decrease from left to right. However, it is important to note that this is not a gradual scale. Instead, the grid diagram just shows significant temperature locations, such as whether a stream starts above or below a pinch.

Applying the three rules of the pinch principle therefore means that there must be no heater on the right hand section of the grid diagram, no cooler on the left hand section and no process heat exchangers between the hot streams on the left hand section and the cold streams on the right hand section. This will ensure that the network will always achieve the energy target.

## The New Design Method





Figure 26: Grid diagram for the example problem

Here, the pinch design method [2, 3] is illustrated, using the example problem shown earlier in Figure 2. The grid diagram for this process is shown in Figure 26. The three rules of the pinch principle are central to the procedure for designing the network. According to the Pinch rules there must be no external cooling above the pinch (on the left side of the grid diagram) so hot streams on this side must be brought to pinch temperature by heat transfer with cold streams on the same side i.e. on the left. Similarly, cold streams on the right hand side of the grid diagram must be brought up to the pinch temperature using hot streams on the right rather than utility heating. The  $DT_{min}$  puts another constraint on the design because it has been defined as the minimum temperature difference for heat transfer anywhere in the system.

## Design Above The Pinch

Some ground rules for setting up the heat exchanger matches between the hot and the cold streams on each side of the pinch (Figure 27) are now considered. Take the example streams shown in Figure 27(a). A proposed match is shown in the inset. Note that the stream directions previously shown on temperature-enthalpy plots have been reversed so that they can be more easily related to the grid diagram. Because the CP of stream 3 is less than stream 1 (CP of cold stream less than CP of hot stream), as soon as a heat load is applied, the temperatures of the two streams converge to closer than  $DT_{min}$ . This means that the proposed heat exchanger is not feasible and another match must be found.






Figure 27: Criteria for temperature feasibility at the pinch

In Figure 27(b), streams 1 and 4 are matched. In this case the CP of stream 4 is greater than the CP of stream 1 (CP of cold stream greater than CP of hot stream). The relative gradients on the temperature-enthalpy plot means that the streams diverge from  $DT_{min}$ ; the match is feasible. For the temperature feasibility of the matches close to the pinch, the CP of the streams going out of the pinch needs to be greater than the CP of the stream coming into the pinch. Thus for temperature feasibility there is a "CP rule":

$$CP_{out} \geq CP_{in}$$

Stream 2 also has to be brought to the pinch temperature and this is achieved using a match with stream 3. Since the CP of stream 3 (stream going out) is greater than the CP of stream 2 (stream going in), the temperature-enthalpy plot is again divergent (see the other inset on 27(b)) and the match is feasible. Now that both the hot streams on the left side of the pinch are completely matched with the cold streams, the possibility of using cooling utility above the pinch has been eliminated. The remaining heating load on the cold streams must now be provided by the utilities.

Since stream 1 requires 240 kW of cooling and stream 4 needs 240 kW of heating on the left side of the pinch, the 1-4 match satisfies the requirements of both the streams. But the 2-3 match can only satisfy stream 2 since stream 2 can only give up 90 kW of heat before it reaches the pinch temperature. This will heat stream 3 to 125°C but the target temperature is 135°C. An extra 20 kW must be provided by utilities to satisfy the heating requirements of stream 3. This is indeed the minimum utility requirement for the network (at  $DT_{min} = 10^\circ\text{C}$ ).

Figure 27(c) shows the completed design for the section to the left of the pinch.

PinchExpress gives a lot of help with this task because of a powerful feature called "Automatic Remaining Problem Analysis". This means that every time a change is made, it can instantly be seen if that change will lead to an energy penalty in the finished design.

## Design Below The Pinch

Figure 28 shows the equivalent design below the pinch (on the right of the grid). The rule below the pinch is not to use utility heating so streams 1 and 3 are matched. The inset shows that the match is feasible since the CP of stream 1 (the stream going out of the pinch) is greater than the CP of stream 3 (the stream going into the pinch). As expected, the temperature-enthalpy plots diverge as they leave the pinch.




Figure 28: Network design below the pinch

It is important to realise that the "CP rule" for temperature feasibility is only rigid for units directly adjacent to the pinch. In the example, Figure 28(b) shows that the proposed match between streams 2 and 3 displays converging temperatures on the temperature-enthalpy plot. However, since the match is not adjacent to the pinch, it does not have to bring the streams to the pinch temperature difference. This means that, even though the temperatures converge, they do not necessarily end up at a temperature difference smaller than  $DT_{min}$ . In this instance, the final DT is greater than  $DT_{min}$  and the match is still feasible.

Figure 28(b) shows the completed design to the right of the pinch. Putting a heat load of 30 kW on the 2-3 match (all the cooling that stream 3 can provide before it reaches its target temperature) means that residual cooling of 60 kW must be provided to stream 2 by utilities.

## Completed Minimum Energy Requirement Design

The overall network resulting from the above and below pinch designs is shown in Figure 29 and is known as a minimum energy requirement (MER) design since it meets the minimum energy target.



There is also a problem if there are matches at the pinch that do not comply with the  $CP_{out} = CP_{in}$  rule. In this case, an incoming stream could be split to reduce its CP. Consider the example shown in Figure 31(a). One of the solutions is to split the incoming stream with CP of 10 (see Figure 31(b)). This network design requires only one split and it achieves the minimum energy requirement as well as the temperature feasibility. One of the objectives in network design is to minimise the number of stream splits. Stream splitting is explained in more detail in reference [2, 3].




Figure 31: Incoming stream split to comply with  $CP_{out} = CP_{in}$  rule.

Figure 32 summarises the rules for stream splitting during network design.  $N_{IN}$  and  $N_{OUT}$  are the number of streams coming in and going out of the pinch respectively.




Figure 32: A summary of stream splitting procedure during network design

## Network evolution: Heat load loops and heat load paths

After the network has been designed according to the pinch design rules it can be subjected to further simplification and capital-energy optimisation. The figures below illustrate the degrees of freedom available for network evolution after the pinch design method.




Figure 33: A heat load loop

Figure 33 shows a degree of freedom called the "Heat Load Loop" [2, 3]. The loop is shown by the solid line marking a circuit between matches 2 and 4. Heat duties can be shifted around a loop without affecting the heat duties imposed on other units in the network which are not part of the loop. This may result in reducing the heat load on a unit to zero (e.g. exchanger 4). However such a change will affect the temperature driving forces in the network. The temperature driving force will become less than  $DT_{\min}$  and in some cases it may result in temperature infeasibility. The cost saving in installation of a unit needs to be compared with increase in the surface area due to the reduction in temperature difference.

Such an optimisation can be carried out in the SuperTarget Process Module developed by Linnhoff March. PinchExpress can also be used to shift heat loads around loops. In many situations using heat load loops can reduce both the number of exchanger units and the overall network cost.




Figure 34: A heat load path

Figure 34 illustrates the second degree of freedom for network evolution called the "Heat Load Path" [2, 3]. A path provides a continuous connection between two utilities and therefore allows the transfer of heat loads between heat exchanger units and the utilities. In Figure 34 the path connects heater, exchangers 2, 4 and the cooler. By changing the heat loads of exchangers 2 or 4, the heater and cooler heat loads will change by the same amount but in an opposite manner. This is demonstrated below in Figure 35. The heating duty can be eliminated if the duty on exchanger 2 is increased by the corresponding amount. Then the cooling duty must also be decreased by this amount to maintain the energy balance on the hot stream. Heat load paths exploit capital-energy trade-off in specific parts of the network. SuperTarget Process and PinchExpress also have the facility to optimise the network performance using heat load paths.




Figure 35: Using a path to reduce utility use

Heat load loops and paths provide additional degrees of freedom for the designer in order to further simplify the network or reduce the overall network cost.

## Network design for multiple utilities

The example for network design as demonstrated previously uses one hot and one cold utility. For processes involving multiple utilities, all the utilities are incorporated in the grid diagram as streams. The network is therefore "balanced" in enthalpy terms. The grid diagram also incorporates all the utility as well as process pinches.

The network design for multiple utilities is more complex due to the occurrence of multiple pinches in the problem. References [2, 3] are appropriate for further background on network design involving multiple utilities. PinchExpress incorporates features for the placement of multiple utilities.

## Summary: New heat exchanger network design

The steps to be followed in network design for a grass roots project can be summarised as follows:

a) Develop a Minimum Energy Requirement (MER) network

- Divide problem at the Pinch
- Start at the pinch and move away
- Start with biggest stream "IN"
- Observe  $CP_{OUT} \geq CP_{IN}$ , splitting streams where necessary
- Place all pinch matches first
- Maximise loads on all pinch matches to minimise number of units (the "tick-off" rule)
- Fill in the rest
- Merge above and below the pinch designs

b) Evolve the MER network for network simplicity and capital-energy trade-off

- Exploit heat load loops and heat load paths
- Optimise network performance using advanced tools in SuperTarget Process

Retrofit design can be carried out using one of the following three methods.

1. Pinch Design Method with maximum re-use of existing exchangers
2. Correction of Cross-Pinch Exchangers
3. Analysis of Exchanger Paths

The retrofit design methods are illustrated using screen shots from Linnhoff March's PinchExpress package.

Which Retrofit Method is Suitable?

The first step in retrofit design is to decide which retrofit method is most suitable for the project. The hierarchical diagram shown in Figure 36 indicates when each of the three methods is suitable. Detailed explanation of the methods is provided below .




Figure 36: Hierarchy of retrofit design

### Pinch Design Method with maximum re-use of existing exchangers

This method has been described in the previous section for design from grassroots. The method is briefly described for retrofits as:

- a) Delete the existing network as shown in Figure 37
- b) Re-design the network by following the Pinch Design Method
- c) Re-use existing exchangers in place of new ones between the same streams




Figure 37: Delete existing network before applying the pinch Design Method

## Correcting Cross-Pinch Exchangers

In situations where the existing network already involves many process-process heat exchangers, it is not appropriate to delete the entire network in order to apply the Pinch Design Method. Instead, it is better to apply a method that makes incremental changes to the existing network, with a corresponding quantification of the benefits.

This is particularly true of processes with diverging composite curves and significant use of intermediate utilities. Indeed, for such a process it is usually possible to discover a series of independent retrofit projects, each involving just a few modifications to the network. It is then possible to rank these projects and just choose the best ones according to some practical or economic criteria.

The method is described in the following flowchart:




Figure 38: Procedure for correcting cross-pinch exchangers

An Ammonia Synthesis example will be used to explain the steps involved in this method. The Balanced Composite Curves for this example (Figure 39) show a scope for saving of 98.4% with a significant use of intermediate utilities.




Figure 39: Example for retrofit design using Cross-Pinch Analysis

Use cross-pinch analysis to find a promising project in the current network

1. From the 'Pinches' report of the potential savings window, identify the pinch region with the largest monetary savings potential and note the corresponding pinch temperature, Figure 40.

Potential Savings <Q values in MMBtu/hr>						
Pinch Region	%OverTgt[\$]	Utilities	Cross-pinch IN	Excess Heating MMBtu/hr	Cross-pinch OUT	Excess Cooling MMBtu/hr
Above U:377.09	134.8 %	C: HP Steam (gen)	0	0	27.8	-27.8
Above U:287.09	-18.9 %	H: MP Steam	27.8	-3.58E-1	21.8	5.62
		C: MP Steam (gen)				
Above U:98.32	-18.7 %	H: LP Steam	21.8	-5.61E-1	12.3	9.03
		C: LP Steam (gen)				
Above U:46.91	7.6 %	C: Cooling Water	12.3	0	-4.16	16.4
Above U:19.91	-5.6 %	C: Chilled water	-4.16	0	-1.11E-1	-4.05
Below U:19.91	-0.7 %	C: C3(-25C)	-1.11E-1	0	0	-1.11E-1

Figure 40: Pinches report indicate that the most significant pinch region is U:377.09 (HP-Steam (gen))

2. From the 'Penalties' report of the potential savings window, identify the exchanger with the largest cross-pinch duty in this region (see Figure 41). Alternatively, use the Energy Penalties graph for the same purpose..

Pinch	HX	Penalty MMBtu/hr	HX Name	Problem
Across U:377.09	2	26.4	FDEF	Cross-pinch
	4	1.39	Q_D-6	Cross-pinch
Above U:287.09	4	4.23	Q_D-6	MP Steam (gen) (Ba
Across U:287.09	2	17.1	FDEF	Cross-pinch

Figure 41: The largest penalty at U:377.09 is exchanger FDEF

3. Determine what will be required to correct the cross-pinch. The options are as follows:

a) Reduce the duty of the exchanger, or delete it altogether. This can be tested by simply editing the exchanger and seeing if there is a benefit (according to the Summary report of the potential savings window). Save the data file first, so that you can undo the change if necessary by reloading the file.

If this approach is used on a complete network then the reported savings can be achieved by simply replacing the duty with appropriate heaters and coolers. In other cases, there may be a need for additional heat exchange with the previously unmatched streams.

b) Move one end of the exchanger to a different utility. This can be done by simply dragging the end of the match with the mouse. Again, the Summary report will immediately show any benefit

c) Look for projects involving two or more exchangers. For example, remove the cross-pinch by changing one of the inlet temperatures rather than reducing the duty. However, to do this you must compensate by a corresponding change to adjacent exchangers, heaters or coolers.

As with option (a), you can test the benefit of changing several matches by deleting them together and observing the reported savings. Again, save the data file first, so that you can undo the change by just reloading the file.

In the example, virtually all of the savings can be achieved by removing the cross-pinch in exchanger "FDEF". This is done by decreasing the hot inlet temperature to FDEF and reducing the duty of the cooler (Q\_D6) by a corresponding amount. We can prove the benefit of this by temporarily deleting FDEF and Q\_D6 and observing the increase in the "%SinceBase" column on the Summary report of the potential savings window (see Figure 42).


Pinch	HX	Penalty MMBtu/hr	HX Name	Problem
Across U:377.09	2	26.4	FDEF	Cross-pinch
	4	1.39	Q_D-6	Cross-pinch
Above U:287.09	4	4.23	Q_D-6	MP Steam (gen) (Ba
Across U:287.09	2	17.1	FDEF	Cross-pinch

Figure 42: The benefit reported after deleting exchanger FDEF and cooler Q\_D6

## Use the Grid Diagram to design the project

Having identified a suitable project we then redesign the network to achieve it. This is done using the Grid Diagram and the Flexible Design Tool in PinchExpress. At the end of this step the network should be complete again. This is checked by observing that the value reported for the Remaining Problem should be zero. This value is found at the bottom of the Summary report of the potential savings window (Figure 43). If the Remaining Problem is not zero, this value will also be reported in the caption for the Grid Diagram window.

For the example, the completed design involves decreasing the hot inlet temperature to 663°F, reducing the duty of Q\_D6 by 26.44 MMBtu/Hr and inserting a HP steam generator with the same duty.



Utility	QTarget	QNow [MMBtu/hr]	%OverTgt[\$]	%SinceBase[\$]
Total			-4.6 %	103.0 %
Total Hot	9.18E-1	8.11E-1	-0.2 %	-2.0 %
Total Cold	47.2	47.1	-4.4 %	105.1 %
C: Chilled wa	4.24	1.91E-1	-5.6 %	0.0 %
C: Cooling W	11.6	15.6	1.9 %	5.7 %

Summary | Pinches | Penalties

Figure 43: The savings achieved after completing the design

## Other steps

For our example we achieve all the savings with just one project. In more complicated examples, several separate projects will be required to achieve all the savings. These can then be ranked to decide which should be given highest priority. Note that at any step in the cycle there may be several possible projects. In this case, process specific knowledge can be used to decide which is the most promising.

## Analysis of Exchanger Paths

In cases where the composite curves are parallel, and there is little or no requirement for intermediate utilities, it may be very difficult to correct cross-pinch exchangers without redesigning the entire network. In this case analysis using heat load paths provides a useful approach.

A path is a sequence of exchangers that connect a hot utility to a cold utility via an odd number of process-process exchangers. The significance of this is that a path provides the opportunity to increase process integration by increasing the heat duty of the process-process exchangers, whilst reducing the hot and cold utility requirements.

The overall procedure for path analysis is summarised below.

1. Identify the paths in the network.
2. Decide the value to use for EMAT (Exchanger Minimum Approach Temperature), which is the minimum allowable temperature difference for the exchangers on a path. This is usually less than the overall DT<sub>min</sub> used for the composite curves. A value of 10 °C is common.
3. Increase the duty of the process-process exchangers along the path until one or more of the exchangers becomes a bottleneck (because its temperature driving force has fallen to EMAT).
4. If the full savings potential has not been achieved, try to remove the bottleneck by modifying branch

flow fractions in split regions.

5. Also, try to remove the bottleneck by moving exchangers to a more favourable position. For example, re-sequence exchangers if one has excess driving force and another is the bottleneck. Alternatively, insert a split so that the driving forces are spread more evenly.
6. Increase the duty of exchangers on the path again until the full savings potential has been achieved.
7. Use heat load loops to re-distribute the driving forces in the network, thereby reducing overall area requirement

Note: The Flexible Design Tool is the main tool for editing the duties on loops and paths in PinchExpress.

Retrofit Example




Figure 44: Example requiring Path Analysis for retrofit design

An example with parallel composites and little requirement for intermediate utilities is shown in Figure 44. Although the savings potential is large, the contribution from intermediate utilities is not significant. This therefore means that to achieve the full savings, heat that is presently rejected to cooling water must be recovered into cold process streams that presently rely on furnace duty. This heat shift involves a wide temperature span and the modifications required will be nearly equivalent to a complete re-design of the existing network. In order to avoid such major changes, it is often preferred to identify opportunities where fewer modifications can be made to achieve some of the potential savings.




Figure 45: Parallel composite curves with no intermediate utilities.






Figure 47: Modifying two paths saves 14.74MMkcal/h.

By increasing the duties of these two exchangers forming a path, a saving of 14.74 MMkcal/h has been achieved, see Figure 47. The full potential is 19.1 MMkcal/h. To save the remaining 4.36 MMkcal/h, it is necessary to make some modifications to the network to increase the driving force on these two exchangers.




Figure 48: Drag and drop of exchanger to a new position improves driving force on path exchangers

A simple way to modify the network structure is by using the drag and drop tool in PinchExpress to move an exchanger from one position to another. For instance, the minimum approach temperature of 10°C occurs at the cold-end of exchangers E5 and E6. This can be dealt with by moving one of the three exchangers below the split junction to above the split junction. For instance, if exchanger pa3 can be moved to another position, the inlet temperature to the exchangers at the split junction will be 60.9°C, instead of 130.3°C. This means that the approach temperature for exchangers E5 and E6, at the cold end, becomes 79.4°C instead of 10°C. The improvement in driving force can then be used to increase the duty of these exchangers on the paths, and further increase the energy savings.




Figure 49: With driving forces improved, the two paths can now be used to achieve the full savings potential

In Figure 49, exchanger pa3 has been moved downstream of the splitter, just before E4. This sufficiently opened up the driving force for E6 duty to be increased to 26.94 MMkcal/h. The network shown in Figure 49 now meets the target hot and cold utility requirements. However, it has an uneven distribution of temperature differences, which is likely to lead to a high overall area requirement. This DT distribution can be improved by shifting heat around loops. The final retrofit network, after re-distributing the driving forces is shown in Figure 50.






Figure 51: Example Process Flowsheet

Figure 52 shows a literal data extraction from the flow-sheet on an exchanger by exchanger basis resulting in the network design on the right. This network design is identical to the one in the original flow-sheet. The engineer performing the study would naturally conclude that the original design is optimal and that the application of pinch technology has resulted in no benefit.




Figure 52: Original Data Extraction and Design

Figure 53 shows an appropriate method of data extraction from the flow-sheet. All the three cold streams previously extracted can be equated to just one cold stream as shown, and likewise only one hot stream needs to be extracted. The resulting design is much simpler from capital cost view-point and shows significant additional potential for improved energy recovery (the network can achieve much lower  $DT_{min}$ ). The "proper" data extraction does not close off any potential energy saving opportunities.




Figure 53: Improved Data Extraction and Design

The message is simply that the engineer should be careful in separating the relevant stream data from the solution features of the previous design. This does require a certain skill and experience along with some knowledge of the process itself. However the principles explained in the following sections [3] should make it possible for an experienced process engineer without much experience in Pinch Technology to extract the data without significant errors.

Do not mix streams at different temperatures

One common problem in data extraction occurs when the process flow-sheet involves the mixing of process streams at different temperatures. When the streams are at different temperatures, the mixing junction then acts as a direct contact heat exchanger. An existing exchanger is clearly part of the existing feature and should not be extracted as it is with the stream data. Figure 54 below illustrates the problems with such a data extraction. Figure 54(a) shows a part of an existing flow-sheet where two process streams at different temperatures are mixed together. The mixing junction could involve cross-pinch heat transfer, as shown in Figure 54(b), and therefore increase the overall process energy requirement. To avoid this, it is advised that if mixing must take place due to process reasons, the streams involved in mixing should be extracted as being mixed at the same temperature as illustrated in Figure 54(c).




Figure 54: Mixing at different temperatures may involve in-efficient cross-pinch heat transfer thus increasing the energy requirement.




Figure 55: Isothermal mixing avoids cross-pinch heat transfer so do not mix at different temperatures.

Figure 55 summarises the data extraction rule regarding non-isothermal mixing in flowsheets. The correct data extraction must consider isothermal mixing. The temperature for isothermal mixing (T) can be chosen according to convenience.

This rule has significant benefit but can imply significant changes to the process flowsheet. For example, the existing heat exchangers will no longer match the stream duty. For this reason it is not applied automatically in PinchExpress. Instead, the rule must be applied manually by changing the simulation or editing the data after transferral into PinchExpress. In SuperTarget Process, however, the user is indeed given the option of applying the rule automatically.

## Extract at effective temperatures

For data extraction, the effective stream temperatures are more important than the actual stream temperatures. For example, for a hot stream it is important to know what temperature it is available at to exchange heat against cold streams, rather than its actual temperature. Similarly, for cold streams it is the temperature at which heat must be supplied to them that is important. Consider the example in Figure 56. A reactor product stream is released at 1000°C and is to be cooled to 500°C. The important feature of this product cooling is that it must be quenched, during which steam is raised (e.g. ethylene process reactor product quenching). As a result of this restriction, the temperature at which the heat in the product stream is available to other streams is not 1000°C to 500°C but the temperature at which steam is raised. It would be incorrect to extract the stream temperatures as from 1000°C to 500°C. The energy target would be over-optimistic. Extracting at the effective temperature (condensing steam temperature) gives the correct target.




Figure 56: Every stream must be extracted at the temperature at which it is available to other process streams.

## Extract streams on the safe side

The enthalpy change of some streams is significantly non-linear. This is particularly true for condensing/vaporising streams. In such situations, adopting just one value of CP might lead to inaccurate results. It is more accurate to represent the stream in as many "segments" as is required to closely mimic the heating and cooling curve of the stream. However, the position of the extracted stream with respect to the actual stream curve is also important. In Figure 57(a), the extracted stream (straight line) is colder than the actual stream at the high temperature end. If there is a hot stream hot enough for the extracted stream but not hot enough for the actual stream, an infeasible match will result. Figure 57(b) features safe side extraction because the actual cold stream is colder than each of the three extracted segments. To linearise on the safe side (Figure 57(c)) therefore means that:

- The actual hot stream must be hotter than the extracted hot stream
- The actual cold stream must be colder than the extracted cold stream




Figure 57: Stream linearisation, a) and b) could be infeasible, c) is safe side linearisation.

This is not an issue when data is transferred to PinchExpress from a simulation because heating curves are reduced automatically. However, this issue should be kept in mind when entering data manually, in which case it is up to the user to ensure that heating profiles are accurately represented.

Do not extract true utility streams

A true utility stream is a utility stream (i.e., steam, cooling water, refrigerant etc.) that can in principle be replaced by any other stream (process or utility) for heat exchange purposes. A true utility stream should not be therefore extracted as a part of the process. An example of a true utility is cooling water used in an exchanger. Since the cooling water can be replaced by air cooling, refrigerant cooling or process stream heating, this should not be extracted. However, when steam is required in a shift reactor to enhance the shift process, the steam is not a true utility. This is because the steam is not just used for heating but is necessary for the reaction and cannot be replaced by another stream. In such a situation, the steam must be extracted as a cold stream, to be heated from boiler feed-water conditions to the appropriate steam temperature and pressure for the reaction, and then vaporised. Another example that is not so straightforward is when direct steam is used for reboiling a column. If this steam is used just for heating purposes and can be replaced by a reboiler serviced by hot oil, steam or some other hot utility, it would be treated as a true utility and should not be extracted. However, if the reboiling must be via direct injection of steam, then the steam is not a utility and should be extracted as part of the process.

Identify soft data

The temperature, pressure and enthalpy conditions of some streams within a process are open to change within certain limits. Such stream data are termed as "soft" data. An example of "soft" data is the pump discharge pressure immediately upstream to a vaporiser. The pump discharge pressure can be varied within certain limits resulting in a corresponding flexibility in the vaporisation temperature which is therefore soft data. Another example of soft data is the target temperature of a product stream which is to go into storage. The temperature of the stream going into a storage can be within a substantial temperature range.

Soft data should ideally be extracted such that the overall process energy requirement is minimised. For

this, the (+)/(-) principle for process modifications is applied. With the pump discharge pressure being a soft data, the feed vaporiser (a cold stream), should be extracted at the coldest possible temperature.

In general, it is useful to view the preliminary set of composite curves before deciding how best to extract the "soft data" as shown in Figure 58. Figure 58(b) shows a product stream leaving the process boundary at temperature  $T^*$  for product storage. Figure 58(a) shows the composite curves for the overall process.  $T^*$  being greater than the pinch temperature ( $T_{pinch}$ ), useful heat can still be extracted from the stream up to  $T_{pinch}$ . This will further reduce the hot utility target based on the (+)/(-) principle. The appropriate data extraction, therefore, in this case is up to the pinch temperature.




Figure 58: Stream data extraction for "soft data".

Up to this point, heat and power targeting for a single process has been considered. Typically refinery and petrochemical processes operate as parts of large sites or factories. These sites have several processes serviced by a centralised utility system involved in steam and power generation.




Figure 59 shows a schematic of a typical process industry site involving several processes. The production processes, some with their own utilities, are served by a common central utility system. The utility system consumes fuel (e.g. gas and lignite), generates power and supplies the necessary steam through several steam mains. There is both consumption and recovery of process steam via the steam mains. Process furnaces also consume fuel. The site imports or exports power to balance the on-site power generation. The process steam heating and cooling demands and co-generation potential dictate the site-wide fuel demand via the utility system.

Figure 59: Schematic of a site, showing production processes which are operated separately from each other but are linked indirectly through the utility system.

Usually the individual production processes and the central services are controlled by different departments. A number of different business units may occupy different subsections of the site and operate independently. The site infrastructure therefore usually suffers from an inadequate overview. To rectify it requires a simultaneous approach to consider individual process issues alongside sitewide utility planning in the single context of making products from feedstocks with minimum use of capital and energy in all forms. Total site improvement using pinch technology provides an aid to sitewide planning for reduction in energy and associated emissions. The SuperTarget Site module allows Engineers to undertake the type of total site projects described in this section.

#### Total site data extraction

The heating and cooling requirements of the individual processes are represented by their respective grand composite curves. The grand composite curve lays open the process-utility interface for a single process. The grand composite curves can be used in identifying potential heat recovery via steam mains for a small number of processes. However, for a site involving several production processes (say 40), the grand composite curve of each process will suggest different steam levels. The identification of correct compromise in steam levels and loads will therefore become quite complex for a realistic site.

#### Constructing Total Site Profiles

Pinch technology enables the designer to set utility targets for sites involving several processes [10, 20]. This capability is based on thermal profiles for the entire site called the "total site profiles". Total site profiles are constructed from the grand composite curves of the processes in the site. Figure 60 illustrates the construction of the total site profiles using only two processes (for demonstration purposes only). The construction starts with the grand composite curves of the individual processes as shown in the figure. Prior to the construction of the total site profiles the grand composite curves are then modified in two ways:

- i) Parts of the grand composite curves that are satisfied by the central utility system are isolated. The non monotonic parts, or the "pockets", in the individual grand composite curves are sealed off through vertical lines as shown in Figure 60. Also parts of the curve directly satisfied by a non-central utility (such as furnace heating within a process) are excluded from the analysis. The remaining parts are the net heat source and sink elements to be satisfied by the central utility system. The source elements as identified in the figure are C and G while the sink elements are A, B, D, E and F as shown in Figure 60.
- ii) The source and sink elements of the resulting grand composite curves are shifted by  $1/2 DT_{min}$ . Source element temperatures are reduced by  $1/2 DT_{min}$  while the sink element temperatures are increased by  $1/2 DT_{min}$  as shown in Figure 60. This temperature shift reverts the temperature scale back from shifted to real temperatures.

The construction of the total site profiles from the modified grand composite curves is also shown in Figure 60. The construction simply involves the generation of "Composite Curves" from the shifted source and sink elements. The composite of the source elements is called the "Site Source Profile" while that of the sink elements is called the "Site Sink Profile". For illustration purposes, the individual sink elements (A, B, D, E and F) and source elements (C and G) have been highlighted throughout Figure 60. The temperature shift as shown in Figure 60 ensures that the total site profiles are in real temperatures.




Figure 60: Construction of Total Site Profiles from process grand composite curves

## Adding steam users not accounted in process stream data

Site source sink profiles primarily originate from the process grand composite curves. There are other steam requirements which are not represented in the grand composite curve. These are:

- Steam for ejectors, reactors, etc.
- Tracing steam
- Unaccountable steam usage

These need to be considered in determining the correct utility system for the site. These steam demands are considered as sink elements and are added to the site sink profile without any temperature correction.




Figure 61: Total site targeting for fuel, co-generation, emissions and cooling

## Total site analysis

### Setting total site targets

The total site targets are developed via a combined use of Total Site Profiles and a Steam System Simulator (e.g. Linnhoff March's Steam package). Figure 61 illustrates site-wide utilities targeting based on total site profiles and steam system simulation. The figure shows the corresponding utilities schematic and total site profiles with the utilities placed appropriately. Note that the vertical axis is now changed from temperature to Carnot factor  $(1-T_0/T)$ . This allows direct visualisation of co-generation as shown by the shaded area in Figure 61.

The target for MP steam generation from all the processes is D. This partly satisfies the MP demand. The remaining targeted MP demand (C) is provided by the turbine system. The targeted HP steam demand for all the processes is (B). Thus the turbine system needs to satisfy MP steam demand (C) and HP steam demand (B). Using steam system simulation software the co-generation (W) and generating steam requirement at VHP level (A) are calculated. The shaded area also indicates co-generation (W). From the VHP load the fuel requirement (F) can be calculated using a standard boiler model in the steam system simulator. This is indicated by a horizontal projection of the fuel profile on the enthalpy axis on total site profiles. Knowing the fuel composition the fuel related emissions can be calculated. The cooling demand for the total site as identified by the total site profiles is E. Thus starting from individual process grand composite curves and using a steam system simulator targets can be set for site fuel, co-generation, site emissions and cooling. The steam level placement against total site profiles is in real temperatures the same as the total site profiles.

The steam system simulation involves the simulation of the turbine system and the boiler house. The model can be used to evaluate the co-generation and fuel consumption. In addition the model can be used to check the constraints of the existing equipment along with changes in steam demand, steam level, fuel type, power demand, utility costs, boiler feed water heating etc.

## Case study - Total site analysis

The use of total site profiles is illustrated with the following example, which relates to a site expansion project [10, 20]. The example shows how the procedure can identify options that result in significant capital cost savings and lower operating costs than conventional solutions.




Figure 62: Existing site

Figure 62 above shows the example site with six processes as operating prior to the expansion project. The existing utility system and the total site profiles are shown. The high pressure (HP) steam mains receives steam from the central turbine system(190 MW). The medium pressure (MP) mains is not connected to the turbine system. At the MP level, steam generation from the processes and consumption by the processes are in balance (30 MW each). The total site profile construction reveals an overall cross pinch heat transfer (in all processes and the utility system) of 40 MW. The site co-generation is 23 MW and site fuel consumption is 282 MW.

A site expansion is planned that involves the introduction of a new process into the existing site. Figure 63 shows the proposed expansion plan with total site profiles and a utility sketch. Both the source and the sink profiles are enlarged as a result of the expansion.




Figure 63: Proposed expansion of the site involving addition of a new process

However, the total site profiles reveal additional information. Since the profiles have changed significantly as a result of the expansion, MP steam is no longer appropriate: it does not exploit the driving forces available between the steam levels and the site sink profile. Pinch analysis indicates that the MP steam pressure needs to be reduced. This is implemented in Figure 64. The reduction in the MP steam pressure has been selected such that MP steam generation is in balance with its use and its load is maximised. Only a small pressure shift was found necessary. As a consequence, the VHP steam demand is reduced significantly.

Comparing the proposed expansion plan (Figure 63) with the alternative plan (Figure 64), it is seen that there is reduction in energy and capital cost as well as a corresponding reduction in emissions (see the table below). The alternative plan does not require investment in a new turbine or a new boiler. It also does not require any expansion in the cooling capacity. The alternative plan shows a reduction of 19% in the utilities operating cost and a global reduction of 15% in emissions.

The initial study subjected the new process to a careful individual optimisation resulting in a minimum energy requirement of 70 MW of MP steam. That steam is to be supplied via a new turbine which links into the existing VHP and MP mains. In order to generate the additional VHP steam (from 213 to 290 MW), a new boiler is planned. Also an expansion of the cooling water system is necessary (from 240 to 280 MW).




Figure 64: Alternative option based on Total Site Profiles

	Proposed Design	Alternative Design
Total utilities operating cost	100%	81%
CO <sub>2</sub> (global)	100%	85%
Capital cost implications	Expand MP steam New turbine New boiler Expand cooling	Shift MP steam and expand Adapt process to suit

Site power demand = 50 MW; cost data: fuel = \$98/(kW.yr), power = \$400/(kW.yr), cooling water = \$5/(kW.yr).

Table 5: Example case study: Comparison of operating and capital costs

Reference [10] provides further options involving process and utilities modifications for the example case study.

By using the total site analysis, the most promising options for utilities and/or process can be screened at the targeting stage. Since steam is simply an intermediate mechanism for heat transfer, its cost is no longer a factor. All designs are directly evaluated in terms of fuel and power at the site boundary. References [1, 28, 30] provide information regarding applications of total site to real projects.

#### Selection of options: Total Site Road Map

Once the site has been translated to total site profiles, modelled with a steam system simulation and different scenarios for site development have been explored, it is possible to establish a relationship between investment and benefit of all the projects in the site. Such a representation is called the "road map" for site development. Each route in a road-map consists of a series of mutually compatible projects. Each project package is explored for its technical and economic feasibility. The designer or planner can use the information from the road-map to plan a "route" or a strategy for long term site development. Figure 65 shows an example of a road map.




Figure 65: Total Site Road Map

#### Summary: Total Site Improvement

Figure 66 summarises the key steps in total site improvement based on pinch technology. The key steps are listed as follows:

This approach provides a high level of confidence that the planning scenario offers the most effective use of the capital. The total site road map can thus combine the information of process wise improvements and sitewide improvements in one coherent plan.




Figure 66: Key steps in total site improvement

- Single Process Pinch Analysis:** Starting from process heat and material balances of individual processes, pinch analysis establishes key options for process modifications, energy recovery (savings in non-central utilities) and targets for multiple utilities. The grand composite curves are ready for total site analysis. Initial trade-off is set between process fuel and steam levels.
- Total Site Pinch Analysis:** Total site profiles are constructed from the individual process grand composite curves and the site infrastructure (e.g. steam system) is simulated. These tools are used together to set targets for infrastructure improvements and process wise improvements. Re-visit step (a) and re-set infrastructure assumptions such as steam mains pressures if they are changed in step (b).
- Identification of Specific Projects:** The targets obtained during individual process analysis are translated into specific network design changes. Simultaneously, the infrastructure improvement options are developed in more detail at an equipment level.
- Final Selection of Project Alternatives (From Total Site Road Map):** The specific projects identified in step (c) are put together in a coherent plan for a total site involving alternative routes of compatible projects. This is followed by final selection of process-wise and infrastructure options for implementation. This stage is followed by project detailing.

1. Linnhoff B, "Use Pinch Analysis to Knock Down Capital Costs and Emissions", *Chemical Engineering Progress*, August 1994.
2. Linnhoff B, D.W. Townsend, D. Boland, G.F. Hewitt, B.E.A. Thomas, A.R. Guy, and R.H. Marsland, "User Guide on Process Integration for the Efficient Use of Energy", *ICHEME*, Rugby, U.K. (1982).
3. Pinch Analysis Foundation Training Course, available from *Linnhoff March Ltd*, UK.
4. "SuperTarget" pinch analysis software suite, available from *Linnhoff March Ltd*, UK.
5. Townsend, D. W., and B. Linnhoff, "Heat and Power Networks in Process Design, Part I: Criteria for Placement of Heat Engines and Heat Pumps in Process Networks", *AIChE J.*, 29(5), pp. 742-748 (May 1983). "Part II: Design Procedure for Equipment Selection and Process Matching", *AIChE J.*, 29(5), pp. 748-771 (May 1983).
6. Linnhoff, B, H Dunford, and R. Smith, "Heat Integration of Distillation Columns into Overall Processes", *Chem. Eng. Sc.*, 38(8), pp. 1175-1188 (1983).
7. Smith, R., and P.S. Jones, "The Optimal Design of Integrated Evaporation Systems", *Heat Recov. Sys. & CHP*, 10 (4), pp. 341-368 (1990).
8. Linnhoff B, and S. Ahmad, "Cost Optimum Heat Exchanger Networks, Part 1: Minimum Energy and Capital using Simple Models for Capital Cost", *Comp. & Chem. Eng.* 14 (7), pp. 729-750 (1990). Ahmad S., B. Linnhoff, and R. Smith, "Part 2: Targets and Design for Detailed Capital Cost Models", *Comp. & Chem. Eng.*, 14 (7), pp. 751-767 (1990).
9. Tjoe, T. N., and B. Linnhoff, "Using Pinch Technology for Process Retrofit", *Chem. Eng.*, pp. 47-60 (Apr. 28, 1986).
10. Dhole, V. R., and B. Linnhoff, "Total Site Targets for Fuel, Co-generation, emissions, and Cooling", *Comp. & Chem. Eng.*, 17 suppl. pp. s101-s109 (1993).
11. Linnhoff, B., and V.R.Dhole, "Shaftwork Targets for Low Temperature Process Design", *Chem. Eng. Sci.*, 47 (8), pp. 2,081-2,091 (1992).
12. Dhole, V. R., and B. Linnhoff, "Overall Design of Subambient Plants", *Comp. and Chem. Eng.*, 18, suppl. pp. s105-s111 (1994).
13. Linnhoff, B., and E. Kotjabasakis, "Process Optimisation: Downstream Paths for Operable Process Design," *Chem. Eng. Progress*, 82 (5), pp. 23-28 (May 1986).
14. Obeng, E. D. A., and G. J. Ashton, "On Pinch Technology Based Procedures for the Design of Batch Processes", *Chem. Eng. Res. & Des.*, 66, pp. 225-259 (1988).
15. Dhole, V. R., and B. Linnhoff, "Distillation Column Targets", *Comp. & Chem. Eng.*, 17 (5/6), pp. 549-560 (1993).
16. Linnhoff B., and D. R. Vredevelt, "Pinch Technology Has Come Of Age", *Chem. Eng. Progress*, 80 (7), pp. 33-40 (July 1984).

17. Linnhoff, B., and G. T. Polley, "Stepping Beyond the Pinch", *The Chem. Eng.*, pp/ 25-32 (Feb. 1988).
18. Smith, R., and B. Linnhoff, "The Design of Separators in the Context of Overall Processes", *Chem. Eng. Res. & Des.*, 66, pp. 195-228 (May 1988).
19. Kotjabasakis, E., and b. Linnhoff, "Better System Design Reduces Heat Exchanger Fouling Costs", *Oil & Gas J.*, pp. 49-56 (Sept. 1987).
20. Linnhoff, B., and V. R. Dhole, "Targeting for CO<sub>2</sub> Emissions for Total Sites", *Chem. Ing. Tech.*, 16, pp. 256-259 (1993).
21. Rossiter, A. P., H. D. Spriggs, and H. Klee, Jr., "Apply Process Integration to Waste Minimisation", *Chem. Eng. Progress*, 89 (1), pp. 30-36 (Jan. 1993).
22. Smith, R., and E. A. Petela, "Waste Minimisation in the Process Industries", "1: The Problem", *The Chem. Eng.*, pp. 24-25 (Oct. 1991); "2: Reactors", *The Chem. Eng.*, pp. 17-23 (Dec. 1991); "3: Separation and Recycle Systems", *The Chem. Eng.*, pp. 24-28 (Feb. 1992); "4: Process Operations", *The Chem. Eng.*, pp. 21-23 (Apr. 1992); "5: Utility Waste", *The Chem. Eng.*, pp. 32-35 (July 1992).
23. Morgan, S., "Use Process Integration to Improve Process Designs and the Design Process", *Chem. Eng. Progress*, 88 (9), pp. 62-68 (Sept. 1992).
24. Brown, K. J., "Process Integration Initiative" (review of the process integration initiatives funded under the Energy Efficiency R&D Programme), *Energy Technology Support Unit, Harwell Laboratory, Didcot, U.K.* (July 1989).
25. Natori, Y., "Managing the Implementation of Pinch Technology in a Large Company", *presented at the IEA Workshop on Process Integration, Gothenburg, Sweden* (Jan. 1992).
26. Trivedi, K. K., K. H. Pang, H. R. Klavers, D. L. O'Young, and B. Linnhoff, "Integrated Ethylene Process Design using Pinch Technology", *presented at AIChE Meeting, Atlanta* (Apr. 1994).
27. Snoek, J., and T. N. Tjoe, "Process Integration Experience in a Large Company", *presented at the IEA Workshop on Process Integration, Gothenburg, Sweden* (Jan. 1992).
28. Rudman, A., et al., "Experience from Total site Integration", *Linnhoff March International, Northwich, U.K.* (1994).
29. Obata, K., and H. Shibuya, "The Challenge of Minimum Energy Plant Design", *presented at Ascope 93, Bangkok* (Nov. 1993).
30. Yoda, H., H. Shibuya, "An approach to Minimum Energy Plant Design Incorporating Pinch Technology and State-of-the-Art Equipment", *presented at the 1995 NPRA Annual Meeting, San Francisco, California* (Mar. 1995).